


NOTE:
REFER TO 6TH FLOOR ENLARGED
PLAN A9.7 FOR MORE DETAILS.

LEGEND

- 1 2-HR EXTERIOR WALL CONST. - STUCCO
2X6 STUDS @ 16" O.C. W/ 2-LAYERS 5/8" TYPE 'X' GYP. BD. @ INTERIOR FACE & 2 COATS OF 1/2" CEMENT PLASTER O.V. 5/8" TYPE 'X' GYP. BD. @ EXTERIOR FACE & R-19 INSULATION.
- 2 2-HR SHAFT
- 3 3-HR AREA SEPARATION WALL
- 4 1-HR CORRIDOR WALL
2X6 STUDS @ 16" O.C. W/ 1-LAYER 5/8" TYPE 'X' GYP. BD. BOTH SIDES & RESILIENT CHANNELS @ 16" O.C. ON ONE SIDE
STC 50 - PER GA FILE WFS242
- 5 PLUMBING WALL
- 6 1-HR INTERIOR PARTY WALL
2X6 STUDS @ 16" O.C. W/ 2-LAYERS 5/8" TYPE 'X' GYP. BD. ON BOTH SIDES
STC 50 - PER P/B/C 2011-063
- 7 4X STUDS INTERIOR WALL
- 8 DRYER VENT WALL, 2-HR FIRE RATED WALL
2X6 STUDS W/ 2-LAYERS 5/8" TYPE 'X' GYP. BD. ON BOTH SIDES
- 9 KITCHEN VENT WALL, 2-HR FIRE RATED WALL
2X8 STUDS W/ 2-LAYERS 5/8" TYPE 'X' GYP. BD. ON BOTH SIDES
- 10 1/2" MAX. FINISH TO FINISH FLOOR DIFFERENCE
- 11 CH
- 12 4H
- 13 W&P
- 14 PANIC HARDWARE
- 15 PORTABLE FIRE EXTINGUISHER - 15 FT. MAX. TRAVEL DIST. FROM ANY FT.

DIMENSION & FINISH NOTES:
1. ALL DIMENSIONS ARE FINISH TO FINISH UNDO.
2. SEE ENLARGED PLANS FOR DETAILED UNIT, DIMENSIONS AND CALLOUTS.



6TH FLOOR PLAN
SCALE: 1/16"=1'-0"

NOT FOR CONSTRUCTION

DATE	REVISIONS
2/28/24	ARCH. REVISIONS
3/4/24	ARCH. REVISIONS

DATE	ISSUED FOR

CONSULTANT

SIGNATURE

PLUS ARCHITECTS
ARCHITECTURE ■ SPACE PLANNING ■ INTERIOR DESIGN

1770 SAWTELLE BOULEVARD ■ LOS ANGELES CA 90025 ■ 310-478-6149

SHEET TITLE
6TH FLOOR PLAN

PROJECT TITLE
THE MANSFIELD 1770 SAWTELLE BOULEVARD LOS ANGELES, CA 90025

DATE	DRAWN	CHECKED	PROJECT
			1301

SHEET **A2.9** OF

P:\Projects\2024\The Mansfield\Architectural\A2.9_6thFloor.dwg, 10/20/24 2:23:38 PM, S:\Users\mch1\11.11